

- **Water Lines**

Water lines may be installed to deliver fresh, or raw water, or both. Water may be withdrawn for non-potable uses by using a gasoline or electric pump. An electric line and water line license is required for electric pumps on public property. The pump, or any electrical component, may not be submerged. Pumps are to be installed on the floating facility. Water lines are not to be submerged; instead they are to be attached to the outside edge or underside of the walkway and dock. Water lines are to be 2 inches in diameter or smaller. Non-potable intakes must be attached to the dock, and all withdrawal apparatuses will not interfere or conflict with public use. Water lines for the withdrawal and subsequent redelivery of water for the purposes of heat pump service is prohibited unless a National Pollutant Discharge Elimination System (NPDES) Permit has been obtained from the State of Georgia.

Potable water lines from private property may be permitted but only one above ground spigot will be authorized on public property. An additional spigot may be installed on the dock. Spigots may not exceed 30 inches in height and shall be attached to a post or other structure. Water lines on floating facilities will be securely attached to the outside edge or underside of the walkway and dock.

New pumphouses and wells are not permitted. Those currently existing will remain as grandfathered (see Page 24). Removal of existing pumphouses will be required if the well is abandoned, inoperative, or its structure needs major repair.

**OTHER REQUIREMENTS:**

- Must show all other permitted items in relation to where the line will be run.
- Water line must terminate on a spigot, or continue onto the dock.
- Water line must be run underground.
- If water line is run onto the dock, it must be run along the gangway to the dock and cannot be submerged at any time.
- If water pump is being used to pump water out of the lake, that must be included on submitted plans.
- Plans must show your property line, the lake, and clearly show where the line runs across Corps property.

Permit #0000



Spigot where water line will terminate.



Proposed new underground water line to dock.



Existing 4' x 50' path to dock



Lot 110

Name of Permit Holder

Street Address

**EXAMPLE**

Cottonw