



# THE MEMPHIS DEPOT TENNESSEE

---

## ADMINISTRATIVE RECORD COVER SHEET

AR File Number 624



TENNESSEE

DR WILLIE W HERENTON - Mayor  
RICK MASSON - Chief Administrative Officer  
DIVISION OF PUBLIC WORKS  
JERRY R COLLINS JR - Director  
Maynard C. Stiles Wastewater Treatment Plant

Friday, May 11, 2001

Mr. Stephen D. Offner  
Project Manager  
CH2M HILL  
115 Perimeter Center Place, Suite 700  
Atlanta, Georgia 30346-1278

RE: Request for disposal of groundwater at the Dunn Field, Defense Depot, Memphis, Tennessee

Dear Mr. Offner:

We have received and approve your request to discharge of 5,115 gallons of treated groundwater into the sanitary sewer. Development and purge water from the above referenced ground water wells has been stored in a number of 55-gallon drums on site. The discharge point is a manhole located at Kyle Street at the west property line of the Defense Depot. The discharge flow rate should not exceed 30 gallon per minute.

This approval is for this batch of treated groundwater only.

If you should have any questions, please feel free to contact me at (901) 353-2392.

Sincerely,

Akil AL-Chokhachi  
Environmental Engineer

cc: Rodney Thomas  
Clyde Hunt  
Memphis Depot Caretaker  
2163 Airways Blvd  
Memphis, Tennessee 38114

**FINAL PAGE**

**ADMINISTRATIVE RECORD**

**FINAL PAGE**