

Client: DDMT

Project: SRI Phase 4

Project Number: 10058697

Site Location: N. of Bldg. 720


Well Installation Diagram

Easting: 802793.2

Logged by: C. Mokri Ground Elevation (NAVD88): _305.2 Well Completion Date: 9/13/2019 Top of Screen Elevation (ft, NAVD): 196.9 Northing: 278489.8 Top of Casing Elevation (ft, NAVD): 305.07

Well: MW-305

Drilling Company: Cascade Bollards: No **Drilling Method:** Gus Pech Sonic Well Diameter (in): 2 Borehole Diameter (in): 6 Well Material: SCH 40 PVC DEPTH (ft)
GRAPHIC LOG Slot Size (in): 0.010 WELL DIAGRAM Type of Filter Pack: Sand Grout Type: Type II Filter Pack Gradation: #10-20 Grout Quantity: 225 gal Filter Pack Quantity: 200 lbs. Well Development Method: Waterra Hydrolift II Bentonite Type: 3/8 in. Chips Well Development Date: 10/10/19 Bentonite Quantity: 75 lbs. Depth to Water (ft. btoc): 93.29



Surface Completion: 8" Diameter Flush Mount Well Box Pad Dimensions: 3 ft. x 3 ft.

Riser Length (ft): 108.2

Depth to Top of Bentonite (ft, bgs): 94.0

Depth to Top of Filter Pack (ft, bgs): 103

Length of Screen (ft): 10

Total Well Depth (ft, btoc): 118.4 Total Boring Depth (ft, btoc): 119

Created By: C. Mokri Created Date: 9/22/19 Checked By: T. Holmes Checked Date: 2/28/20