

Installation DOMT
 Site West of Own Field
 Project Number 113630.01.3Z
 Drilling Contractor Boart Longyear
 Built By Boart Longyear

Well Number MW1-54 (J)
 Client/Project DDMT GW Investigation
 Starting date 09 FEB 96 time 0840
 Completion date time
 Well Coordinates _____

Elevation _____
 Height _____
 GS Elevation _____

DEPTH BGS

Elevation _____
 Depth BGS _____

81 ft

0 ft

81 ft

84.5 ft

14 ft

10 ft

94.5 ft

95 ft

TD: 101 ft

6 ft

6 inch
Borehole dia.

PROTECTIVE CSG

Material / Type _____
 Diameter _____ Water Tight Seal (Y / N)
 Depth BGS _____ Weep Hole (Y / N)

SURFACE PAD

Composition & Size _____

RISER PIPE

Type Schedule 40 PVC
 Diameter 2 inch
 Total Length (TOC to TOS) 84.5 ft

GROUT

Composition & Proportions High Solids (30%)
Bentonite Clay - Pure Goid
 Tremed (Y / N) (N)
 Interval BGS 0 ft to 81 ft

CENTRALIZERS (Y / N)

Depth(s) BGS _____

SEAL

Type N/A
 Source _____
 Hydration Time _____ Volume of Fluid Added _____
 Tremed (Y / N) _____

FILTER PACK

Type 20/40 Silica Sand
 Amount Used 4 50 # bags
 Tremed (Y / N) (N)
 Source The Moric Company
 Gr. Size Dist. Grade 00N

SCREEN

Type Schedule 40 PVC
 Diameter 2 inch
 Slot Size & Type 0.010 inch
 Interval BGS 84.5 ft to 94.5 ft

BACKFILL PLUG

Material Bentonite Pellets
 Hydration Time _____
 Tremed (Y / N) (N)